

Mr. Graham King
Polyflor Limited
PO box 3, Radcliffe New Road, Whitefield
Manchester M45 7NR
England

Your message - reference

-

our reference

PW/847

Gent

2019-04-16

Certification report 19/847

1. Description of the flooring:

Floor covering type	homogeneous polyvinyl chloride floor coverings
Total mass	2.800 g/m ²
Nominal thickness	2.0 mm

2. Test results:

Classification according to EN 13501-1:2019

Class	EN ISO 11925-2 or CWFT (EN 14041 - 2004)	EN ISO 9239-1 (30 min.)
B_{fl}	E _{fl} (F _s ≤ 150mm within 20 s.)	heat flux ≥ 8.0 kW/m ² smoke < 750%. min

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.



CENTEXBEL • textile competence centre • www.centexbel.be

GENT • Technologiepark 7 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • gent@centexbel.be

VAT • BE 0459.218.289 • **IBAN •** BE 44 2100 4729 6545 • **BIC •** GEBABEBB

addressee

polyflor

our reference

PW/846

Gent

2019-04-16

page

2

test method and test number	Parameter	no. Test	results	
			continiuos parameters - mean (m)	compliance with class B _{fl} -s1 parameters
EN ISO 11925-2:2010	FS (mm)	6	< 150 mm within 20s	compliant
	flaming droplets/particels		No	compliant
EN ISO 9239-1: 2010	critical flux (kW/m ²)	3	9,3 kW/m ²	compliant
	smoke (%.min)		297 %.min	compliant

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

Loose laid on a combustibile substrate¹

B_{fl} - s1

Related commercial names to this product group

Polyflor Palettone PUR

The obtained classification is based on the next test report(s)


Centexbel: 19.00930.09 dd 2019-04-01

Validity of the certificate

2024-03-31

Petra Wittevrongel

Product Certifier



¹ End use substrates of wood and of classes A1 or A2-s1,d0 (ISO 13238:2010 § 5.2.3)